

H₂O



Athens Utilities Board 2006 Water Quality Report

(Data Table on Back)

AUB's Water Division provides water in the city of Athens and McMinn County. The water we delivered in 2006 surpassed the strict regulations of the state of Tennessee and the U.S. Environmental Protection Agency. If you have any questions, contact Jill Davis, AUB Water & Wastewater Superintendent, at (423) 745-4501.

AUB board meetings are held on the fourth Tuesday of each month at 5:00 PM. You can get on the agenda by calling AUB at least one week prior to the meeting.

Where Does AUB's Water Come From?

AUB obtains drinking water from three sources: a spring that has been in use for

decades; three wells that tap an aquifer in the Oostanaula Creek basin, and; the Hiwassee River via purchases of treated water from the Hiwassee Utilities Commission (HUC). Water from the spring and wells is pumped to AUB's filter plant where state-licensed operators work 365 days a year to provide water that surpasses all state and national water-quality standards.

AUB has a Wellhead Protection Plan, available for review at our office, upon request.

Further, the Tennessee Department of Environment and Conservation has prepared a Source Water Assessment Program Report for untreated water sources. The report assesses the susceptibility of untreated water sources to potential contamination. To ensure safe drinking water, public water systems treat and routinely test their water. Water sources are rated as reasonably susceptible, moderately susceptible, or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. AUB's rating is reasonably susceptible. For an explanation of the Tennessee Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings, and to see TDEC's report to EPA, go to <http://www.tennessee.gov/environment/dws/dwas sess.shtml> or contact AUB to obtain a copy of our assessment.

Information about Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling EPA's Safe Drinking Water Hotline at 1-800-426-4791.

As water travels over land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activity. To ensure top

water quality, AUB operators have collected samples and tested your water for a variety of chemicals and contaminants. Those that were detected are listed in the Water Quality Table of this report. The table describes the existing EPA/TDEC maximum contaminant level (MCL), maximum contaminant level goal (MCLG), AUB and HUC results, and potential sources from where the contaminants originated.

Some people may be more vulnerable to contaminants found in drinking water than others. Individuals with weakened immune systems, such as those with cancer, those who have undergone organ transplants, people with HIV/AIDS, some elderly, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by microbial contaminants are also available at EPA's hotline telephone number.

AUB Water Plant Top in State for 2006

The Tennessee Water Works Association named AUB's water filter plant the state's top water plant for 2006.

The TWWA Chairman said that few plants in American can consistently produce water of the quality produced by AUB

The exceptional quality of water produced at the AUB plant is a direct reflection of the people who operate it.

We're Your Neighbor, Your Utility

Athens Utilities

Athens Utilities Board – 2006 Water Quality Table

Parameter	Units	Year Performed	AUB Result	HUC Result	Regulatory Limit MCL	Goal MCLG	Source
-----------	-------	----------------	------------	------------	----------------------	-----------	--------

REGULATED AT THE WATER TREATMENT PLANT

Turbidity	NTU	2006	0.14	0.41	TT	TT	Soil Runoff
Range			0.04-0.14	0.04-0.41			
Fluoride	ppm	2006	1.23	1.6	4.0	4.0	Additive that promotes strong teeth; Erosion of natural deposits
Range	ppm		0.83-1.23	0.11-1.6			
Nitrate	ppm	2006	1.2	0.19	10.0	10.0	Fertilizer use, septic tanks, erosion of natural deposits
Total Organic Carbon	ppm	2006	0.75 avg.	0.71 avg.	TT	TT	Naturally present in the environment. We met the Treatment Technique requirements for Total Organic Carbon in 2006.
Range			0.5-1.5	0.54-0.71			
Sodium	ppm	2006	1.5	1.9	-	-	Erosion of natural deposits

REGULATED IN DISTRIBUTION SYSTEM AND CUSTOMER TAP

Total Coliform Bacteria (% positive samples)		2006	0	0	5	5	Naturally present in the environment
Total Trihalomethanes	ppb	2006	18.7	45 avg.	80	0	By-product of drinking water chlorination
Range	ppb		3-64	17-87 ¹			
Haloacetic Acids	ppb	2006	14.4	41 avg.	60	0	By-product of drinking water chlorination
Range	ppb		2-41	22-65 ²			
Chlorine	ppm	2006	1.56 avg.	2.0 avg.	MRDL=4	MRDL=4	Water additive used to control microbes
Range	ppm		0.9-3.0	0.7-2.5			
Lead (90%)	ppb	2006	1.7	n/a	15	15	Corrosion of household plumbing. One of the 30 samples tested was above EPA's action level
Range	ppb		0.5-17				
Copper (90%)	ppb	2006	450	n/a	1,300	1,300	Corrosion of household plumbing. None of the 30 samples tested were above EPA's action level
Range	ppb		38-600				

NOTE: In 2006, AUB incurred no violations for contaminant levels, monitoring, or reporting requirements prescribed by the state and EPA. The two Hiwassee Utility Commission results that are footnoted below are from sample locations outside of the AUB service area.

To help you understand more fully the data in this table, these definitions and explanations may be helpful:

- BDL – “Below Detection Level”.
- MCL – “Maximum Contaminant Level”. The highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG’s as feasible using the best available treatment technology.
- MCLG – “Maximum Contaminant Level Goal”. The level of a contaminant below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- MRDL – “Maximum Residual Disinfectant Level”. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- MRDLG – “Maximum Residual Disinfectant Level Goal”. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- ppb – “part per billion”. One part in a billion parts (equivalent to one penny in \$10,000,000).
- ppm – “part per million”. One part in a million parts (equivalent to one penny in \$10,000).
- TT – “Treatment Technique”. A required process intended to reduce the level of a contaminant in drinking water.
- NTU – This stands for “Nephelometric Turbidity Units” and measures the clarity of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The EPA has two requirements: (1) The maximum level found must be less than 1 NTU; and (2) The level must be under 0.3 NTU 95% of the time.
- HUC - Hiwassee Utility Commission
- AUB conducts water quality testing every day and has tested your water for many substances not included in the table, like pesticides, herbicides, metals, and solvents. None of these substances were detected using prescribed EPA analytical methods.

¹ Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

² Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.